



Tripura Housing & Construction Board

[Office of the Dy. Executive Officer (H&B)]

Agartala : Tripura

(Constituted under Tripura Act No 2 of 1979)

Dated : 24.07.2026

F.02(64)/DEO(H&B)/THCB/2022/314

To
✓ The Principal
Bodhjung H.S school
North-Banamalipur, Agartala

Subject : Issuing the Building Safety Certificate

Ref : Your Letter vide F-2(29)/PNCL/BJHS/VIDYAJYOTI/2026/97; dated 14th July 2026.

Sir,
In pursuance to your above letter under reference, Building Safety Certificate comprising Part-I and Part-II is issued by T.O and also appended herewith. The said certificate has been issued following the recent inspection of the entire school building by our technical members.

Enclosure : As stated above

Yours' faithfully,

[Er. S. Banik]

Dy. Executive Officer(H&B)
Tripura Housing and Construction Board

PART-I

PERFORMA FOR THE SAFETY OF SCHOOL BUILDING

(To be filled by the Head of school Institution)

(a) Name of the School: Construction of Bodhjung Boy's H.S School, Agartala /S.H: Building portion including water supply & sanitary installation (Phase-I & II).

(b) Level/Standard of School: Higher Secondary School

(c) Whether School is affiliated to C.B.S.E orYes.....
P.S.E.B. If affiliated then affiliation No.2020162.....

1) Location : North Banamalipur, Agartala, West Tripura

2) Plot Area : 9988.59 m

3) Plinth Area : 5940.00 Sqm

4) Number of Storey : 02 (Two) Storey

5) Year of construction of building: 2026

6) If the building has been constructed under the Supervision of the

Qualified Engineer, the following details may be given :
(a) Name of the Engineer with Qualification: Sri Dipak Chowdhury (Civil Engineer)
(b) Address of the Engineer: DEO(H&B), TH&CB, Gurkhabasti, Agartala,
(c) Detail of structural drawings used in the construction: R.C.C isolated & combined footings, Tie beam, Plinth beam, Staircase, Column, Floor beam, Floor slab, Roof beam, Roof slab.

(d) Name & Address of Architect with qualification: Kakali Acharya (B. Arch.), Architect, TH&CB, Gurkhabasti, Agartala, West Tripura.

7) Whether the building has been constructed for the purpose of

(a) School: Yes

(b) Residential purpose and converted for use as a school: No

8) Material used for roofs

(a) R.C.C slabs: R.C.C Slabs

(b) R.S Joists & Battens: No

(c) Wooden Joists & Battens: No

9) Material used for walls

(a) Mud mortar: No

(b) Cement mortar: Yes

(c) Plaster i) Lime mortar: No

ii) Cement mortar: Yes

10) Flooring:-

(a) Conglomerate: Marble stone, Ceramic floor tiles, Kota stone etc.

(b) Terrazo: No

(c) Brick paving: No

11) A detailed drawing indicating dimensions of the rooms along with size and location of doors and windows:
Drawing Enclosed

12) Whether fire safety certificate obtained from concerned fire officer

13) It is also certified that there is no court case, dispute with any party or stay is pending regarding this School, in any Hon'ble Court.

(Principal)

Bodhjung Boy's H.S School, Agartala, West Tripura
Affiliated with C.B.S.E
Vide Aff. No. 2020162

(MALAY BHAUMIK)
Principal
Bodhjung H.S. School,
Agartala, West Tripura.

PART-II

SCHOOL BUILDING SAFETY CERTIFICATE


(To be filled by the A.E.O of Tripura Housing & Construction Board)

Name of the School: Construction of Bodhjung Boy's H.S School, Agartala /S.H: Building portion including water supply & sanitary installation (Phase-I & II).

- 1) The Assistant Executive Officer/Junior Engineer visited the above mentioned school on 17-07-2026 and visually inspected it for its safety and find it fit for normal use as a school building.
- 2) In case any addition or expansion and modification to this building is to be carried out same may be done under the supervision of a technically qualified Engineer and this certificate may again be obtained after the completion from the undersigned.
- 3) In case the building is affected by flood, or if there is settlement of walls/foundation or sagging of roofs etc. immediately inspection of the undersigned be arranged to check the stability and the safety of the building.
- 4) This building is found visually safe hence it is expected that it can be safely occupied for normal use up to December - 2036 (indicate year up to which it can be used) under normal condition.

Ref. No.

Dated : 24/07/2026


(Dy. Executive Officer)

Tripura Housing & Construction Board
Gurkhabasti, Agartala
West Tripura