


No.F.7(14)-CMO(W)-LAW/2019 / 8091
GOVERNMENT OF TRIPURA
OFFICE OF THE CHIEF MEDICAL OFFICER
WEST TRIPURA, AGARTALA.

DATED, AGARTALA, THE ...M.....08/ 2026.

**HEALTH & SANITATION
CERTIFICATE**

This is to certify that the Health, Sanitation & Drinking Water facilities in the premises of the **"Bodhjunga Higher Secondary School"**, Agartala, West Tripura, 799001, West Tripura are in good condition.


(Dr. Amartya Debnath)
District Health Officer
West Tripura, Agartala.

To
Principal
"Bodhjunga Higher Secondary School"
Agartala, West Tripura, 799001

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
P.N. Complex,
Agartala - 799006
Mobile : 9402120089,
Website : www.dws.tripura.gov.in



TC-7350

TEST REPORT

Name & Address of the customer

Headmaster, Water Sample from
Bodhjung H.S. School, North
Banamalipur, Agartala, Tripura
West., Tripura

Report No : SLWTL/2017/6590
Report Date : 29-07-2026
Sample ID : QIZ9VN5WJC
Date of Receipt of Sample : 17/07/2026, 12.30 pm
Date(s) of Performance : 24/07/2026
Ref. No. & Date : Nil
ULR No : TC735025000013692F

We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results :

1.	Description of Sample (As declared by customer)	: Drinking Water
2.	Volume of Sample Received	: 500 ml
3.	Sample Mark (if any, given by the customer)	: NA
4.	Date of Sampling by the Customer	: 17/07/2026
5.	Source & Place of Sampling	: Water Sample from Bodhjung H.S. School, North Banamalipur, Agartala, Tripura West.
6.	Environmental conditions during sampling	: NA
7.	Sampling Plan & Procedures used	: NA

Report
Prepared by

Signature

Name : Ratan Shil

Designation : Technical Manager

For State Level Water Testing Laboratory

Signature

Name : Sujoy Paul

Designation : Quality Manager

Authorized Signatory

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of State Level Water Testing Laboratory, PWD(DWS)
- The reserved part of sample(s) shall be retained for 15 days from the date of Completion of Test.

Contact Person : Dr Sujoy Paul,

Quality Manager, State Level Water Testing Laboratory

Mobile : 9402120089, Email : s.manna.paul@gmail.com, Website : www.dws.tripura.gov.in

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
 P.N. Complex,
 Agartala - 799006
 Mobile : 9402120089,
 Website : www.dws.tripura.gov.in



TC-7350

Report No : SLWTL/2017/6590
 Sample ID : QIZ9VN5WJC

Analysis of Result

SN	Characteristic	Acceptable Limit (as per BIS 10500:2012)	Permissible Limit (as per BIS 10500:2012)	Method of Test	Results
1	Turbidity in N.T.U	1	5	APHA 24th Edition 2130 B	0.91
2	pH value at 25°C	6.5-8.5	No Relaxation	APHA 24th Edition 4500-H+ B	6.51
3	Iron (as Fe) in mg/l	1.0	No Relaxation	APHA 24th Edition 3500-Fe B	0.121
4	Total Dissolved Solids in mg/l	500	2000	APHA 24th Edition 2540 C	105.0

BDL - Below Detection Level for Fluoride - <0.2 mg/l, Arsenic - <0.009 mg/l, Iron - <0.1 mg/l, Magnesium - <2 mg/l, Manganese - <0.01 mg/l49">

Report Prepared by

Signature 
 Name : Ratan Shil
 Designation : Technical Manager

For State Level Water Testing Laboratory

Signature 
 Name : Sujoy Paul
 Designation : Quality Manager
 Authorized Signatory

-: End Of Report :-

Contact Person : Dr Sujoy Paul
 Quality Manager, State Level Water Testing Laboratory,
 Mobile : 9402120089, Email : s.manna.paul@gmail.com, Website : www.dws.tripura.gov.in

DEPARTMENT OF MICROBIOLOGY
AGMC & GBP HOSPITAL

592/Micro/AGMC/Water Sterility 24/07/2026

To
The Principal
Bodhjung H.S. School
Tripura(West)

Date- 30/07/2026

Sub:- Report of microbiological sterility testing of ONE (01) nos. of water sample.


Sir,

I am herewith submitting the sterility report of ONE (01) nos. of water sample sent on 24/07/2026. Details of the investigation are as follows.

Sl. no	Source/ Place of collection	Date	Coliform detected or not	MPN/ 100ml	Remarks
01.	Bodhjung H.S. School	24/07/2026	Detected	01	Acceptable: But make regular sanitary checks.

Yours sincerely,

1.Office copy, Microbiology
2.IDSP Office


Microbiologist
Dept of Microbiology,
AGMC & GBP Hospital,
Agartala, Tripura (West)